VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	08 - Kootenay Lake
School Name:	Adam Robertson Elementary
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes Date of last inspection: 2021-09-08 Date of next inspection: 2021-10-28 Date and type of most recent maintenance:
RECOMMENDATION: Increase supply of outside air	September. Belts and Filters. Yes/No: Yes Detail: 100% outside air until rooms can not be maintained.
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes Detail (Including filter grade): Merv-13 filters on order. Install upon arrival.
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: Yes Detail: Portable air cleaners used/available when needed.
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes Detail: Digital Direct Controls. (DDC)
Other Relevant Information:	
District Contact for any Questions:	Name: Chris Kerr Phone Number: 250-354-4871 Email: Chris.Kerr@sd8.bc.ca